

CITY OF CONWAY, ARKANSAS

Office of the Mayor
1201 Oak Street Conway, Arkansas 72032
Mayor Tab Townsell
Phone 501-450-6110 Fax 501-450-6145



ADDENDUM #1
BID NUMBER 2015-10
Notice Date: January 26th, 2015 @ 10:00am

Information Technology Department
2015-10_Backup Generator & Automatic Transfer Switch Bid Specifications.

Tuesday, January 27th, 2015 @ 10:00am
City Hall, Downstairs Conference Room

A. Purpose

The purpose of this Addendum No. 1 is to clarify the fuel system for the generator bid. It should be noted that the fuel system should be LP gas and not natural gas as indicated on the bid document.

B. Specifications and contract documents special conditions:

- Revise the second bullet point of “One (1) Generator”, to read as follows:
 - “Fuel system – LP gas”

If you have any additional questions regarding this addendum, please contact Lloyd Hartzell, CTO @ lloyd.hartzell@cityofconway.org-ar.gov.